



CERT

# DIN-DVGW type examination certificate

## DIN-DVGW-Baumusterprüfzertifikat

**NW-6365DO0499**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	JCH A/S Karetmagervej 21, DK-7100 Vejle
<b>Distributor</b> <i>Vertreiber</i>	JCH A/S Karetmagervej 21, DK-7100 Vejle
<b>Product Category</b> <i>Produktart</i>	Valves for drinking water: standpipe backflow preventer BA accord. DIN EN 1717 (6365)
<b>Product description</b> <i>Produktbezeichnung</i>	backflow preventer BA for standpipe
<b>Model</b> <i>Modell</i>	Backflow preventer 4-AQUA-PRO
<b>Test reports</b> <i>Prüfberichte</i>	Type testing: 130458-A from 09.12.2022 (DTI) Type testing: 130458-B from 30.01.2023 (DTI) Type testing: 915353 from 17.04.2020 (DTI) Hygienic testing: MO 0158/16 from 05.12.2016 (TZW) Hygiene: KA 0205-16 from 08.12.2021 (TZW)
<b>Test basis</b> <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 12729 (01.02.2003) UBA BWGL-Metalle (11.01.2023) UBA ELASTOM (16.03.2016) UBA KTW-BWGL (07.03.2022) DVGW W 270 (01.11.2007)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / Aktenzeichen</i>	30.01.2028 / 23-0617-WNE

702029-01-1-DE

05.03.2024 Bo A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
2490	Pressure rating: PN 10 Nominal diameter: DN 15 mm	
2490	Pressure rating: PN 10 Nominal diameter: DN 20 mm	
2490	Pressure rating: PN 10 Nominal diameter: DN 25 mm	
2490	Pressure rating: PN 10 Nominal diameter: DN 50 mm	